

Government of Karnataka  
(Public Works Department)

No. Hu:Loi:kattad:suprapa:2023-24/402

Assistant Executive Engineer.

Office of the PWD Sub Division,  
Hukkeri, Date : 20-07-2023.

To:

The Principal,  
K.L.E.School, Sankeshwar  
Tal. Hukkeri. Dist. Belagavi

Sub: Issue of Stability No Objection Certificate to the already constructed old buildings of Private Aided, Un-aided schools and Pre-Degree Junior colleges- to issue Building Stability Certificate reg....

Ref: 1) Government Circular No Loi:59:BED:2019, Bengaluru Dt. 07-05-2022.  
2) Divisional Office Letter No Loi:chivi:sa.im..3:2022-23:210 Dt. 30-5-2022.  
3) Divisional Office Letter No Loi:chivi:sa.im..3:2022-23:1314 Dt.8-06-2022.  
4) Letter from Principal, K.L.E. School, Sankeshwar, Dated 17-07-2023.

Sir,

With reference to above, you have requested for issue of Building Stability Certificate in respect of K.L.E. School Sankeshwar, building situated in Gavanal. As per the directions issued by Government vide their letter No. Loi:59:BED:2019, Bengaluru Dt. 07-05-2022 referred at Ref. (1) above, and as per their circulars in which they have instructed to issue the certificates for the already constructed buildings in existence duly conducting the structural evaluation according to the prescribed parameters and on going through your certificates and accordingly taking into consideration the same Executive Engineer, P.W.D. Division Chikkodi, has instructed vide Ref. No. 3 above, to issue Structural Stability No Objection Certificate at this juncture.

The formats enclosed along with proposal are verified and with regard to conducting the Non-Destructive tests for the buildings constructed within the period of 5 years and it is noticed that it is not mandatory to conduct the Non-Destructive tests as per circular referred at Ref. (1) at it's Sr. No. 4/ii .

The said building is RCC Column Structure and having RCC Roof top. After examining all the reports, it is opined that the building of K.L.E. School, Sankeshwar, situated at Gavanal is suitable. The said letter is issued stating that the said building has provided all the parameters as per N.B.C.-2016 for a period of 5 years and the building is safe and the certificate is issued subject to the following conditions :

- 1) If any alterations are to be made in the building technical consultancy should be obtained.
- 2) The regular maintenance of the building should be undertaken from time to time.
- 3) The building should be used only for the School Activities.

Yours faithfully

  
SECRETARY

Board of Management  
K.L.E. Society, BELAGAVI

Assistant Executive Engineer  
PWD Sub Division, Hukkeri

Branch Officer

TRANSLATED  
"TRUE & CORRECT"

  
B. A. SHINDIHATTI B.A.L.L.B. (SPL)  
ADVOCATE & NOTARY GOVT OF INDIA  
TPO KOCHARI - 591340 TQ HUKKERI  
DIST BELAGAVI M 9008127776

11 JUL 2023



PRINCIPAL

K.L.E. Smt. Malutai Shivaputra Shirakoli School  
At:Gavanal, Post: Kamalnur, Chikkodi-Gotur Road,  
Sankeshwar-591340, Tal.Hukkeri, Dist.Belagavi, Karnataka

No of Corrections

Notary



## BUILDING SAFETY CERTIFICATE


No: 266

Date: 26-06-2025


It is certified from plan of existing building of **KLE SMT. MALUTAI SHIVAPUTRA SHIRAKOLI SCHOOL, SANKESHWAR** located at **GAVANAL** along Gotur-Chikkodi road is having Ground floor and 3floor

The said building is occupied by **KLE SMT. MALUTAI SHIVAPUTRA SHIRAKOLI SCHOOL, SANKESHWAR** had been constructed in year 2022-23 & is visually inspected by **Shri Vijay Y. Khuragade, Junior Engineer, PWD** on 26/06/2025 in the presence of principal of said school has reported that as per visuable observation & rebound hammer test conducted reports it is complied with safety & is fit for occupancy for running school. As per report given the said building is fit for occupancy for period of **01 years** provided following condition are satisfied.


- 1) Building should not be altered without proper technical suggestions for the competent authority
- 2) Annual maintenance & repairs of buildings be done regularly .
- 3) Building should be used for running school only.

  
Section Officer

Signature with Seal

  
Assistant Executive Engineer  
PWD Sub Division Hukkeri

  
**PRINCIPAL**  
K.L.E. Smt. Malutai Shivaputra Shirakoli School  
At: Gavanal, Post: Kamatnur, Chikkodi-Gotur Road,  
Sankeshwar-591340, Tal. Hukkeri, Dist. Belagavi, Karnataka.

  
**SECRETARY**  
Board of Management  
K.L.E. Society, BELAGAVI