

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 23/06/2025

It is certified that an inspection team headed by Er. U. P. KAMBLE Assistant Executive Engineer from Rural Drinking Water & Sanitation Department, Government of Karnataka. Sub-Division Gokak inspected the KLE SMT. MALUTAI SHIVAPUTRA SHIRAKOLI SCHOOL, SANKESHWAR Located AT Gavanal Post Kamatnur on 20/06/2025 and on the basis of Water Test Report (Attached) bearing no: 001 dated 21/06/2025 of Rural Drinking Water & Sanitation Division Laboratory Gokak certified that the KLE SMT. MALUTAI SHIVAPUTRA SHIRAKOLI SCHOOL, SANKESHWAR has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 24/06/2026.


Assistant Executive Engineer

Signature with Seal R.W.S. and S. Sub-Dn. Gokak.

Name : Er. U. P. KAMBLE

Designation : Asst. Executive Engineer

To
The Principal
KLE Smt. Malutai Shivaputra
Shirakoli School, Sankeshwar

Name & Address of the Office / Department:
R.D.W.S & S. Dept. Govt. of Karnataka. Sub Div-
Gokak


PRINCIPAL

K.L.E. Smt. Malutai Shivaputra Shirakoli School
At Gavanal, Post Kamatnur, Chikkodi-Gotur Road,
Sankeshwar-591340, Tal. Huttur, Dist. Belagavi, Karnataka.


SECRETARY

Board of Management
K.L.E. Society, BELAGAVI



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
District:Belagavi Laboratory Name:Gokak Taluka Lab

TEST REPORT

To,
Principal
K.L.E Smt.Malutai Shivaputra Shirkoli School
At:Gavanal, Post: Kamatnur, Chikodi-Gotur Road,
Sankeshwar-591340,
Taluka: Hukkeri
District: Belagavi

Report date: 21-06-2025
Report Number: 001
Reference: Sample receipt Form
Sample receipt date: 20-06-2025
Sample code:001
Date of Sample collection: 20-06-2025
Analysis start date: 20-06-2025
Analysis completion date: 21-06-2025
Sample collection protocol: IS 3025(Part-1)
Sample quantity: 1litre

Sample Particulars: River Water

Sl.No	Test	Results	Acceptable Limit IS 10500: 2012 RA:2018	Permissible Limit IS 10500: 2012 RA:2018	Test Method
1.	pH Value @Temp25.0°C	7.35	6.5 – 8.5	No relaxation	IS 3025 (Part-14) : 2013
2.	Specific Conductance,µS/cm@Temp°C	134	–	–	IS 3025 (Part-5 & 6):2018
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2023
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-4) :2021
5.	Colour, Hazen Units	<5	5	15	IS 3025 (Part-10) : 2023
6.	Turbidity, NTU	0.4	1	5	IS 3025 (Part-16) : 2023
7.	Total Dissolved Solids@ 105°C, mg/l	76.0	500	2000	IS 3025 (Part-23) : 2023
8.	Alkalinity as CaCO ₃ , mg/l	15.92	200	600	IS 3025 (Part-21) : 2009
9.	Total Hardness as CaCO ₃ , mg/l	27.74	200	600	IS 3025 (Part-40) : 2024
10.	Calcium as Ca, mg/l	6.41	75	200	IS 3025 (Part-46) : 2023
11.	Magnesium as Mg, mg/l	2.62	30	100	IS 3025 (Part-32) : 1988
12.	Chloride as Cl, mg/l	5.95	250	1000	IS 3025 (Part-24) : 2022
13.	Sulphate as SO ₄ , mg/l	6.84	200	400	APHA 24 th Edition 4500F-D
14.	Fluoride as F, mg/l	0.05	1	1.5	APHA 24 th Edition 4500 NO3-B
15.	Nitrate as NO ₃ , mg/l	1.0	45	No relaxation	IS 3025 (Part-53) : 2024
16.	Iron as Fe, mg/l	0.07	1	No relaxation	IS 3025 (Part-11) : 2022

Remarks: The above tested parameters are within the Acceptable limits as per specification of IS 10500:2021.

Analysed by:
Analyst

Verified By:
Assistant Executive Engineer
RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
District:Belagavi Laboratory Name:Gokak Taluka Lab

TEST REPORT

To,
Principal
K.L.E Smt.Malutai Shivaputra Shirkoli School
At:Gavanal, Post: Kamatnur, Chikodi-Gotur Road,
Sankeshwar-591340,
Taluka: Hukkeri
District: Belagavi

Report date: 21-06-2025
Report Number: 002
Reference: Sample receipt Form
Sample receipt date: 20-06-2025
Sample code:002
Date of Sample collection: 20-06-2025
Analysis start date: 20-06-2025
Analysis completion date: 21-06-2025
Sample collection protocol: IS 3025(Part-1)
Sample quantity: 1litre

Sample Particulars: River Water (filter)

Sl.No	Test	Results	Acceptable Limit IS 10500: 2012 RA:2018	Permissible Limit IS 10500: 2012 RA:2018	Test Method
1.	pH Value @Temp25.0°C	7.19	6.5 – 8.5	No relaxation	IS 3025 (Part-14) : 2013
2.	Specific Conductance,µS/cm@Temp°C	54	–	–	IS 3025 (Part-5 & 6):2018
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2023
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-4) :2021
5.	Colour, Hazen Units	<5	5	15	IS 3025 (Part-10) : 2023
6.	Turbidity, NTU	0.2	1	5	IS 3025 (Part-16) : 2023
7.	Total Dissolved Solids@ 105°C, mg/l	32.0	500	2000	IS 3025 (Part-23) : 2023
8.	Alkalinity as CaCO ₃ , mg/l	7.96	200	600	IS 3025 (Part-21) : 2009
9.	Total Hardness as CaCO ₃ , mg/l	15.85	200	600	IS 3025 (Part-40) : 2024
10.	Calcium as Ca, mg/l	3.20	75	200	IS 3025 (Part-46) : 2023
11.	Magnesium as Mg, mg/l	1.40	30	100	IS 3025 (Part-32) : 1988
12.	Chloride as Cl, mg/l	3.97	250	1000	IS 3025 (Part-24) : 2022
13.	Sulphate as SO ₄ , mg/l	3.06	200	400	APHA 24 th Edition 4500F-D
14.	Fluoride as F, mg/l	0.02	1	1.5	APHA 24 th Edition 4500 NO3-B
15.	Nitrate as NO ₃ , mg/l	0.46	45	No relaxation	IS 3025 (Part-53) : 2024
16.	Iron as Fe, mg/l	0.04	1	No relaxation	IS 3025 (Part-11) : 2022

Remarks: The above tested parameters are within the Acceptable limits as per specification of IS 10500:2021.

Analysed by:
Analyst

Verified By:
Assistant Executive Engineer
RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01