

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 011

Dated: 13/06/2026.

It is certified that an inspection team headed by Er. S. S. Gasti
Assistant Executive Engineer from Rural Drinking Water & Sanitation Department,
Government of Karnataka, Sub-Division Gokak inspected the KLE SMT. MALUTAI
SHIVAPUTRA SHIRAKOLI SCHOOL, SANKESHWAR located AT Gavanal Post Kamatnur
on 10/06/2026 and on the basis of Water Test Report (Attached) bearing no:
011 dated 13/06/2026 of Rural Drinking Water & Sanitation Division
Laboratory Gokak certified that the KLE SMT. MALUTAI SHIVAPUTRA SHIRAKOLI
SCHOOL, SANKESHWAR has safe drinking water facilities for the students and
members of staff of the institution. School is also maintains the hygienic sanitation
condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 12/06/2027.

Signature with Seal


Assistant Executive Engineer
R.W.S. and S. Sub-Dn. Gokak

Name : Er. S. S. Gasti

Designation : Asst Executive Engineer

To
The Principal
KLE Smt. Malutai Shivaputra
Shirakoli School, Sankeshwar

Name & Address of the Office / Department:
R.D.W.S & S. Dept. Govt. of Karnataka. Sub Div-
Gokak


PRINCIPAL
K.L.E. Smt. Malutai Shivaputra Shirakoli School
At:Gavanal, Post: Kamatnur, Chikkodi-Gotur Road,
Sankeshwar-591340, Tal.Hukkeri, Dist.Belagavi, Karnataka


SECRETARY
Board of Management
K.L.E. Society, Belagavi



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Sub Divisional Water Quality Chemical Testing Laboratory Gokak
 Near Basaveshwar Circle Infront JSS College Gokak 591307
 rdwsd.wqmospgokak@gmail.com

TEST REPORT

To, Customer Name: The Principal Name Of School: KLE Smt. Malutai Shivaputra Shirakoli School, Sankeshwar Name Of Taluka: Gokak Name Of District: Belagavi				Report date: 11-06-2026	
				Report Number: 011	
				Reference: Sample receipt Form	
				Sample receipt date: 10-06-2026	
				Sample code:011	
				Date of Sample collection: 10-06-2026	
				Analysis start date: 10-06-2026	
				Analysis completion date: 11-06-2026	
Sample collection protocol: IS 3025(Part-1)				Sample quantity: 1litre	
Sample Particulars: SW					
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
1.	pH Value @Temp25.0°C	6.58	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 1983
2.	Specific Conductance,µS/cm@Temp°C	56	–	–	IS 3025 (Part-14) : 1984
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1983
5.	Colour, Hazen Units	<5	5	15	IS 3025 (Part-4) :1983
6.	Turbidity, NTU	0.2	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids@ 105°C, mg/l	30	500	2000	IS 3025 (Part-16) : 1984
8.	Alkalinity as CaCO ₃ , mg/l	7.96	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO ₃ , mg/l	11.88	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	1.61	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	1.26	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/l	3.97	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	2.72	200	400	IS 3025 (Part-24) : 1986
14.	Fluoride as F, mg/l	0.05	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO ₃ , mg/l	1.08	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/l	0.07	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: The above tested parameters are within the Acceptable limits as per specification of IS 10500:2021.					
Analysed by:  Analyst RDW&S Sub-divn,Gokak.			Verified By:  Assistant Executive Engineer RDW&S Sub-divn,Gokak.		

Note:


RDWSD/WQMSP/TeR/01

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Sub Divisional Water Quality Chemical Testing Laboratory Gokak
Near Basaveshwar Circle Infront JSS College Gokak 591307
rdwdsd.wqmospgokak@gmail.com

TEST REPORT

To, Customer Name: The principal Name Of School: KLE Smt. Malutai Shivaputra Shirakoli School, Sankeshwar Name Of Taluka: Gokak Name Of District: Belagavi				Report date: 11-06-2026	
				Report Number: 012	
				Reference: Sample receipt Form	
				Sample receipt date: 10-06-2026	
				Sample code:012	
				Date of Sample collection: 10-06-2026	
				Analysis start date: 10-06-2026	
				Analysis completion date: 11-06-2026	
Sample collection protocol: IS 3025(Part-1)				Sample quantity: 1litre	
Sample Particulars: SW Raw water					
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
1.	pH Value @Temp25.0°C	7.21	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 1983
2.	Specific Conductance,µS/cm@Temp°C	105	–	–	IS 3025 (Part-14) : 1984
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1983
5.	Colour, Hazen Units	10	5	15	IS 3025 (Part-4) :1983
6.	Turbidity, NTU	1.8	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids@ 105°C, mg/l	61	500	2000	IS 3025 (Part-16) : 1984
8.	Alkalinity as CaCO ₃ , mg/l	10.0	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO ₃ , mg/l	24.02	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	5.33	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	2.12	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/l	4.07	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	0.72	200	400	IS 3025 (Part-24) : 1986
14.	Fluoride as F, mg/l	0.08	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO ₃ , mg/l	7.51	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/l	0.12	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: The above tested parameters are within the Acceptable limits as per specification of IS 10500:2021.					
Analysed by:  Analyst RDW&S Sub-divn,Gokak.			Verified By:  Assistant Executive Engineer RDW&S Sub-divn,Gokak.		

Note:

RDWSD/WQMSP/TeR/01

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01